

**RFP 2023-21-066P  
ADDENDUM #1**

**Civil Engineering Services for Topographic Surveys  
Oceanside Multiple Schools**

The following changes, additions, deletions, clarifications, or corrections shall become part of the Request for Proposals for the above-listed project. This Addendum #1 forms part of the RFP document and modifies the original documents. **Addendum #1 MUST be acknowledged in the cover letter.** Failure to do so may subject the response to disqualification.

Oceanside Unified School District	Program Management: CCM/MAAS
RFP 2023-21-066P Civil Engineering Services – Oceanside Multiple Schools for Topographic Survey	Program Manager: Penny McGrew

<b>Informational Updates</b>
1.
2.

<b>Question</b>	<b>Response</b>
1. Will scope exhibits for Stuart and Santa Margarita be provided? These appear to be missing from the provided documents.	Yes, these will be provided at a later date.
2. Is there civil engineering design scope that is part of this RFP	No. There may be add-on services to address grading and draining improvements is topography survey indicates such design is required.
3. Is any Right-of-Way or Boundary information desired as a part of this project?	At locations where survey ties to public way for site access, show/designate properly line locations(s)
4. What interval/frequency of spot shots and other surface details would be preferred (ex.5 foot spacing)?	1'-0" ideal for most paths of travel areas, 5'-0" to 10'-0" max for larger asphalt/paving areas is acceptable, however, capturing abrupt changes in grade is required.
5. Shall the topographic survey be tied into the City's control network for Basis of Bearing & Benchmark, or do	Tie to City's control network.

**RFP 2023-21-066P  
ADDENDUM #1**

**Civil Engineering Services for Topographic Surveys  
Oceanside Multiple Schools**

the sites have local control that would be preferred.	
6. Will site access be during school operation or after school (or weekend work) preferred?	District will coordinate access for each site through the administrative office. But surveys can be done during school operation.
7. What is the desired turn-around time for these projects?	2-weeks is preferred.
8. Will the Notice to Proceed (NTP) be site by site or will all sites be part of a single NTP?	One NTP to cover all projects.
9. Is this project subject to prevailing wage?	Yes.
10.	
11.	

Bid due date has been changed to January 4<sup>th</sup>, 2023 via email to: [fredparker@maasco.com](mailto:fredparker@maasco.com), no later than 2:00 PM.

END OF ADDENDUM #1